



September 20, 2023,

File: 21020-50/WW/OP/Stoughton

Town of Stoughton
Box 397
STOUGHTON, SK S0G 4T0

Dear Mayor and Council:

RE: Rescinding - Precautionary Drinking Water Advisory – Town of Stoughton

The Water Security Agency, in consultation with the Saskatchewan Health Authority, are advising that the **“Precautionary Drinking Water Advisory” (PDWA)** issued by the Water Security Agency for a portion of the Town of Stoughton’s distribution system **(200 and 300 Block of Main Street)** potable water system be rescinded as of September 20, 2023..

The rescinding of the PDWA was based upon information provided by your community, which included:

- Water main repair has been completed, and all associated appurtenances have been flushed according to applicable standards;
- Turbidity and chlorine residuals throughout the WTP and distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permit to operate.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Town of Stoughton addressing the advisory.

Should you have any questions or concerns, please call me at (306) 551-9412.

Sincerely,

A handwritten signature in blue ink, appearing to read "Rod Broughton", is written over a horizontal line.

Rod Broughton
Environment Officer
Water Security Agency

cc. Roger Miller - Water Security Agency
Saskatchewan Health Authority - Weyburn