



May 1, 2024

File: 21020-50/WW/OP/Stoughton

Town of Stoughton
Box 397
STOUGHTON, SK S0G 4T0

Dear Waterworks Owner/Operator:

This letter is to advise you that a Precautionary Drinking Water Advisory (PDWA) will be placed on a portion of the Town of Stoughton's water distribution system. This advisory is effective May 1, 2024, at 1:00 PM, until further notice. The portion affected is as follows:

**Main Street South
Sullivan Street
Stanley Street**

**Walter Street
Elizabeth Avenue**

Water Security Agency (WSA) protocol, in consultation with Saskatchewan Health Authority, is to place water distribution systems under a PDWA when a watermain repair results in a depressurization of the water distribution system, until such time as the water within the water distribution system is proven safe for human consumptive use. This PDWA remains in effect until the safety of the Town of Stoughton's distributed water can be ensured. Therefore, the administration shall notify all affected users of the water distribution system of the conditions in the attached PDWA poster.

This PDWA can be rescinded by the WSA once the following is completed:

- 1) The break has been repaired, and all related appurtenances have been disinfected and flushed according to applicable standards.
- 2) The receipt of **two consecutive sets of three (6 total) bacteriological samples**, collected 24 hours apart from representative locations within the area of the water distribution system affected, which are analyzed and found to be negative for bacteriological presence. Samples are to be marked as "Other" and labeled with the appropriate station number in order to expedite their processing. These samples will not count towards sampling compliance.

For further information please do not hesitate to contact the undersigned at (306) 551 9412 or rod.broughton@wsask.ca.

Sincerely,

A handwritten signature in blue ink that reads "Rod Broughton".

Rod Broughton
Environment Officer
Water Security Agency
cc: Roger Miller - Water Security Agency
Saskatchewan Health Authority – Weyburn Office

Precautionary Drinking Water Advisory

This Advisory applies to a portion of the Town of Stoughton and is effective May 1, 2024, at 1:00 PM until further notice. The portion affected is as follows:

Main Street South	Walter Street
Sullivan Street	Elizabeth Avenue
Stanley Street	

Pursuant to clause 36(1)(a) of *The Environmental Management and Protection Act 2010* this Precautionary Drinking Water Advisory is issued due to water main repair resulting in a portion of the Town having to be depressurized in order to complete the repair and therefore the safety of Stoughton's drinking water supply cannot be ensured at all times. Therefore, pursuant to Clause 36(1)(b) of *The Environmental Management and Protection Act 2010*, consumers must be notified to:

- (a) boil all water, used for drinking purposes, for at least one (1) minute, at a rolling boil, prior to use;
- (b) boil water to be used for other activities where it may be ingested, including:
 - (i) brushing teeth or soaking false teeth;
 - (ii) washing fruits and vegetables;
 - (iii) food or drink which will not be subsequently heated; and
 - (iv) ice cubes;
- (c) not use the water for washing dishes, unless the water has been boiled or the dishes are sanitized in another fashion. Washed dishes and utensils can be soaked in a bleach water solution (approximately 2 tablespoons of bleach per gallon or 10 ml of bleach per liter of water) for at least two minutes after being washed to kill any bacteria which may be present.
Note: Do not mix bleach with soaps or detergents.
- (d) not drink from any public drinking fountains supplied with water from the public water supply;
- (e) ensure that younger children and infants are sponge bathed;
- (f) use an alternative water source known to be safe, if they do not wish to boil the water; and
- (g) consult with your physician if you have cuts or rashes that are severe before using the water.

Under most circumstances, there is no need to boil water used for other household purposes. Adults, adolescents and older children may shower, bathe or wash using tap water but should avoid swallowing the water. Laundry may be washed in tap water, either by hand or by machine.

This Advisory is effective as listed above, and will not be lifted until the water supply is determined to be completely safe.

Residents and operators of public facilities may access detailed precautions for PDWAs/EBWOs online at <https://www.saskhealthauthority.ca/Services-Locations/RRPL/Pages/Water-Quality-and-Testing.aspx>

If you require any additional information, please contact the following:

Town Office	306-457-2413
Water Security Agency –Science and Licensing Division	306-551-9412
Sask. Health Authority, Weyburn Office	1-888-295-8005

For media inquiries, please contact comm@wsask.ca and request to speak to a media spokesperson. Please be sure to identify your name, media outlet and contact information.

Rod Broughton
Environment Officer
Water Security Agency